



HMR GROUP

HMR INTERNATIONAL SCHOOL

Date: 30/08/2023

To,
The Authorised Officer,
Bangalore Water Supply and Sewerage Board,
Bengaluru -560043

**Sub: Regarding the Certificate of Safe Drinking
Water & Sanitary Condition Certificate**

Respected Sir/Madam,

As per the above cited subject, we would like to request you for the issue the Certificate of Safe Drinking Water & Sanitary Condition Certificate for our Institution **HMR International School, #41/1, 9th Main, 11th Cross, HBR 4th Block, Hennur Maruthi Layout, Bengaluru-560043.**

The report of bacteriological analysis certificate has been enclosed for your kind perusal.

We kindly request you to issue the certificate over the proceedings from the department.

Please do the needful.

Sincere regards,

H M Ramesh Gowda,
Chairman,
HMR International School



HMR INTERNATIONAL SCHOOL

No.41/1, 9th Main, 11th Cross,
Hennur Maruthi Layout, HBR 4th Block,
Kalyan Nagar Post, Bangalore-560043.


GOVERNMENT OF KARNATAKA

No:PHI/Water/BAC/ 422/ 23-24

Office of the Joint Director
Public Health Institute
Bengaluru - 560 001

Dated: 28/08/2023

Report of Bacteriological analysis of Water/Effluent sample

Sample No.	Source & Particulars of Water Sample	Opinion				
		M.P.N Count	Plate Count	D.C Test	S.P.P	N.S.P.P & FC.
1331	Filter water	Nik	-	-	SPP	-
<p>Note: M.P.N Count: Most probable number of Bacteria per 100ml of Water D.C Test: Differential Coliform test Plate Count: Plate Count per ml of sample SPP: Water is satisfactory for Potable purpose NSPP: Water is not satisfactory for Drinking purpose NSPP & FC: Water is not satisfactory for Drinking purpose and E.Coli found</p>						

For Joint Director (Labs)
PUBLIC HEALTH INSTITUTE
Bengaluru

(FTO)

Advice:

1. Sample.....

Need effective chlorination before use

2. Sample.....

Need to avoid possible source of faecal contamination and effective chlorination before use
For the purpose of chlorination. Refer the Annexure enclosed.

STANDARD FOR THE DRINKING WATER

		Presumptive Coliform count per 100ml	E coli count per 100 ml
CLASS 1	Excellent	0	0
CLASS 2	Satisfactory	1-3	0
CLASS 3	Suspicious	4-10	0
CLASS 4	Unsatisfactory	Greater than 10	0.1 or More

ಕ.ಆ.ಸ. ಪ್ರಪತ್ರ ೧ (ಅನುಚ್ಛೇದ ೬)
ಹಣ ಸ್ವೀಕರಿಸಿದ ಬಗ್ಗೆ ಸ್ವೀಕೃತಿ ಪತ್ರ

BNG/2019/MAY

4127089

1331

ಸಾ.ಆ. ಸಂಸ್ಥೆ, ಬೆಂಗಳೂರು
ಇವರ ಕಛೇರಿ

ಸ್ಥಳ.....

ದಿನಾಂಕ 10.5.2023

ಇದಕ್ಕಾಗಿ 1125/- (ಒಂದನೇ ಸಾವಿರ ರೂಪಾಯಿಗಳಿಗೆ ಸೀಳು)

ರೂಪಾಯಿಗಳನ್ನು H.M.R. International School
Bengaluru ಇವರಿಂದ

ಸ್ವೀಕರಿಸಲಾಗಿದೆ ಮತ್ತು ನಗದು ಪುಸ್ತಕದ ಸಂಖ್ಯೆ ಪುಟದಲ್ಲಿ ನೋ
ಬಾಬಿನಲ್ಲಿ ರಂದು ಜಮೆ ಮಾಡಲಾಗಿದೆ.

For Joint Director (Lab)
Public Health Institute
Seshadri Road, K.R. Circle,
Bengaluru - 560 001.

ನಗದು ಗುಮಾಸ್ತ